

7
Norplex Division
N. E. County Road • P.O. Box 427 • Postville, Iowa 52162
Telephone 319-864-7321

August 12, 1981

CON 12-7-1 NEW FACILITY - NORPLEX
JHCU BR
RECEIVED
AUG 25 1 02 PM '81
DEPARTMENT
ENVIRONMENTAL QUALITY

Mr. Joe P. Sanfilippo,
Environmental Specialist
Iowa Department of Environmental Quality

RE: Hazardous Waste Inspection IAD-073489288

Dear Mr. Sanfilippo:

We completed the construction of a dike around our hazardous waste storage area on Monday, August 10, 1981. The dike is constructed of cement block and will easily contain 300 gallons of spilled material (10% of maximum volume that can be stored). Since this was the only deficiency noted that required additional work, we should now meet all of the requirements.

If you need any additional information on the dike, please let us know. Thank you for your help.


Sincerely,

Polk A. Burleson

Polk A. Burleson
Supt.-Engrng. & Maint.

cc: C. Englebert
C. Rochester
J. Devenport
G. Stunyo


R00330119
RCRA RECORDS CENTER



UOP

Universal Oil Products Company

